

NORTHERN GREECE CERAMICS S.A.

Nea Santa 61100 - Kilkis, Greece Tel: 0030 23410 75570

Fax: 0030 23410 75574 Email: info@kebe-sa.gr web: www.kebe-sa.gr



13

EN 1304:2005

Macedonian Roof Tile

Clay Roofing Tiles and Fittings for Roof Covering and Wall Cladding

| DOP Reference No | Mac-19 | |
|--|----------------------------------|--|
| Flexural Strength (not valid for fittings) | Pass | |
| External Fire Performance | Deemed to Satisfy | |
| Reaction to Fire | A1 | |
| Water Impermeability | Pass Category 1, Test Method 2 | |
| Dimensions and Dimensional Variation | Pass | |
| Durability (Frost Resistance) | Pass, Test Method E (150 cycles) | |

Particular conditions applicable to the use:

Cutting with power tools may generate dust. People undertaking works of this nature are advised to wear suitable personal protective equipment (PPE)













Declaration of Performance

Clay roofing tiles and fittings

No: Mac-19

Unique identification code of the product-type: Macedonian Roof Tile

Intended Use/es: Roof Covering and Wall Cladding

Manufacturer: NORTHERN GREECE CERAMICS S.A.

Nea Santa, 61100 - Kilkis,Greece Tel: 0030 23410 75570 Fax: 0030 23410 75574 Email: info@kebe-sa.gr web: www.kebe-sa.gr



System/s AVCP: System 4

Harmonised Standard: EN1304:2005

Declared Performance/s:

| Declared Ferrormance/s. | | | |
|---|------------------------------------|---------------------------------------|--|
| Essential Characteristics | Performance | Harmonized Technical Specification | |
| Flexural Strength (not valid for fittings) | Pass | EN 538 | |
| External Fire Performance | Deemed to Satisfy | EN 13501-5 | |
| Reaction to Fire | A1 | EN 13501-1 | |
| Water Impermeability | Pass Category 1, Test Method 2 | EN 539-1 | |
| Dimensions and Dimensional Variation | Complies | EN 1024 | |
| Durability (Frost Resistance) | Pass Test Method E (150 cycles) | EN 539-2 | |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

George Koutsoupas - Quality Systems Manager

Nea Santa 21/10/2019

